

Certificate of Approval Number A/13933E

Authorised marking: A/13933E

This is to certify that ITACS has approved the electrical equipment described hereunder and authorises the certificate holder to affix the abovementioned mark to products of the same type; or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled

Declared class: Non declared
Product: Nedap type PR series Photovoltaic grid connected inverter
Input: 150-600Vd.c.
Output: 230V a.c. 50Hz IP20
PR30S:3000W; PR37S: 3700W; PR50S: 5000W
Models without battery back-up
PR30SB-XX:3000W; PR37SB-XX:3700W; PR50XX-PR:5000W
Models with battery back-up: 24Vd.c
"XX" = BU, PR or SU for marketing purpose only

Certified to the relevant requirements of:

AS 4777.2:2005
AS 4777.3:2005
AS/NZS 3100:2009

Certificate Holder: N.V. Nederlandsche Apparatenfabriek "Nedap"
Parallelweg 2; 7141 DC
Groenlo
The Netherlands

Conditions:

This certificate is not transferable and remains the property of ITACS
This certificate may only be reproduced in full
This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the standards listed above.
This certificate is granted subject to the conditions and obligations as set out in the ITACS Electrical Product Safety Certification application form.

Signed for and on behalf of issuing body



Certification Authority

Issue date: 08/09/2011
Expiry date: 08/09/2016

 <p>ABN 60 098 886 563</p>	<p><i>Certificate issued by</i></p> <p>International Testing And Certification Services Pty. Ltd. 4-6 Second Street SA 5007 Australia PO Box 300 Hindmarsh SA 5007 Australia Phone: +61 8 8346 8680 <i>Email: itacs@itacslab.com</i></p>	 <p>Accreditation by the Joint Accreditation System of Australia and New Zealand Acc No. Z2870404AA www.jas-anz.org</p>
---	---	--